

Globe Battery Regeneration Test

- 1.Period : Feb 4 -
- 2.Place : Globe Telecom Aurora MSC
3. Manufacturer : FIAMM 12V100AH
4. Manufactured Date : 2004.11.18
- 5.Discharging Voltage 10.5 V Current 26.6A
- 6.Standard Internal Resistance : 5.1mOhm
- 7.Battery Pattern : No.8 2.35 Start

Item	Initial Value		1st Discharging				Regeneration by ZBR-201				
No	Voltage	IR (Ohm)	Date	RC (Min)	Voltage	IR(Ohm)	Group	Date	30M(V)	90M(V)	Time
FM1	12.59	4.65	2/7	119	11.53	8.69	2	2/9	12.5	12.6	15H
FM2	12.25	11.76	2/7	21	11.84	17.15	5	2/12	12.6	13.3	17H
FM3	12.78	5.72	2/7	83	11.88	10.92	1	2/8			561M
FM4	12.76	7.32	2/7	50	12.41	11.31	3	2/10	13.3	13.4	17H
FM5	12.95	6.44	2/7	62	12.04	13.76	1	2/8			561M
FM6	12.78	7.71	2/7	69	11.98	16.06	1	2/8			561M
FM7	12.76	6.33	2/8	86	12.08	12.72	1	2/8			561M
FM8	12.54	8.45	2/8	12	12.3	10.89	3	2/10	13.2	13.3	17H
FM9	12.75	9.01	2/8	5	12.32	16.65	5	2/12	14.8	16.1	17H
FM10	12.64	6.64	2/8	20	12.4	10.15	3	2/10	13.2	13.3	17H
FM11	12.52	8.22	2/8	5	12.44	12.86	3	2/10	13.1	16.1	17H
FM12	12.12	20.38	2/11	5	11.16	29.44					
FM13	12.48	5.52	2/8	77	11.93	8.97	2	2/9	12.3	12.7	15H
FM14	12.52	6.05	2/8	14	12.24	11.45	3	2/10	13.3	13.6	17H
FM15	12.59	9.29	2/8	5	15.52	13.6	4	2/11	14	14.9	17H
FM16	12.22	15.42	2/11	5	12.01	27.1					

FM17	12.76	6.49	2/8	13	12.64	8.75	2	2/9	13.5	16.6	15H
FM18	12.17	21.16	2/11	2	12.1	28.12					
FM19	12.78	6.04	2/8	22	12.59	8.39	2	2/9	13.3	16.1	15H
FM20	12.75	6.65	2/8	20	12.51	13.25	4	2/11	13.3	13.5	17H
FM21	12.05	8.2	2/8	5	12.3	17.06	5	2/12	15.2	16	17H
FM22	12.76	8.45	2/8	5	12.64	13.93	4	2/11	15.4	16.1	17H
FM23	12.73	6.18	2/8	14	12.48	9.38	2	2/9	12.45	16.4	15H
FM24	12.56	7.34	2/8	9	12.19	12.52	3	2/10	13.1	15.8	17H
FM25	12.75	5.88	2/8	19	12.36	8.9	2	2/9	12.5	16.3	15H
FM26	12.56	9.13	2/9	11	12.43	14.39	4	2/11	13.3	15.7	17H
FM27	12.73	11.48	2/9	5	12.08	22.19					
FM28	12.59	7.66	2/9	10	12.19	13.42	4	2/11	13.4	16.2	17H
FM29	12.76	5.74	2/9	17	12.51	21.04					
FM30	12.27	9.59	2/9	32	11.84	19.34	5	2/12	12.1	12.9	17H
FM31	12.08	9	2/9	10	11.79	15.37	4	2/11	12.5	12.5	17H
FM32	12.06	8.48	2/9	30	11.87	17.55	5	2/12	12.2	12.6	17H
FM33	12.01	9.3	2/9	25	11.74	16.44	5	2/12	12.01	12.5	17H
FM34	12.56	6.07	2/12	50	12.17	10.38	6	2/13	13	13.1	
FM35	12.68	6.92	2/12	5	12.41	13.13	6	2/13	15.9	16.3	
FM36	12.76	6.77	2/12	97	12.01	13.34	6	2/13	12.8	12.9	
FM37	12.65	6.82	2/12	6	12.22	17.3					
FM38	12.57	6.96	2/12	18	12.28	10.51	6	2/13	13.2	15.1	
FM39	12.54	7.38	2/12	7	12.17	11.19	6	2/13	14.5	15.9	
FM40	12.67	8.6	2/12	15	12.3	13.71	6	2/13	13.3	15.8	
FM41	12.08	8.94	2/13	1	11.98	15.43					
FM42	12.67	8.33	2/13	7	12.28	22.98					

13.1	5.33						
13.08	5.3						
13.07	5.48						
13.08	5.43						
13.13	5.7		67	12.25	9.17		
13.07	7.77	2/12	59Min	12.44	9.25		
12.84	6.43						
13.08	5.17						
13	7.25	2/12	56Min	12.49	10.08		
12.99	6.38						
12.94	5.95		123	11.98	12.09		
12.59	5.06						
13.04	4.08						
13	4.35						
	4.99						
	4.63						
	5.98		82	11.93	11.08		
	5.94						
	5.82						
	7.06						

Remarks
High IR
Short RC Time
Short RC Time
Short RC Time
Short RC Time
High IR
Short RC Time
Short RC Time
High IR

